



January 6, 2022

ALEX ARINELLO
SUPERIOR MD NO 1 - PWSID CO0107725
127 E COAL CREEK DR
SUPERIOR CO 80027

RESCIND OF TIER 1 BOIL WATER ADVISORY

Dear ALEX ARINELLO:

The Colorado Department of Public Health and Environment-Water Quality Control Division (the “Department”) issued a “Boil Water Advisory” for the Town of Superior (the “Supplier”) on **December 31, 2021** due to a **loss of pressure to the System due to an operational issue. Loss of pressure may allow disease-causing organisms to enter the water system.**

Since the “Boil Water Advisory” was issued, the Department has received the following information from the Supplier:

- The Supplier flushed the distribution system in order to ensure that the distribution system is properly restored.
 - Chlorine residuals in the distribution system were brought down to normal levels after the flush.
- The Supplier provided a written description of flushing activities and demonstrated that adequate flushing had been performed.
- Confirmation that the samples taken were free from the presence of total coliform bacteria and volatile organic compounds.
- Service connections damaged by the fire were identified and service was suspended to those addresses.
 - Note: the Department considers that any service connection damaged by the fire could present an unacceptable health and/or safety risk to the public and therefore are considered cross-connections. Any service connection damaged by the fire must be tracked and managed to ensure potential contamination cannot enter the distribution system in accordance with Section 11.39 of the Colorado Primary Drinking Water Regulations, Regulation 11.
 - Consult with the department for additional sampling and follow-up on these service connections.

Based upon the actions taken by the Supplier, the “Boil Water Advisory” is hereby rescinded. Effective date of this action is **January 6, 2022**. The affected customers should be notified of the lifting of the “Boil Water Advisory.” Public notice of the lifting of the “Boil Water Advisory” should include contact information for the water system and should be provided in a similar manner to

which the initial advisory was issued. A template can be created at wqcdcompliance.com/pn under “Problem Corrected”.

Please note, rescindment of the “Boil Water Advisory” does not constitute compliance with public notification requirements. If not already completed, the Supplier must submit the certificate of delivery and copy of the original public notice to fulfill the regulatory public notification requirements for the “Boil Water Advisory”.

If you have any further questions, please contact me at 303-916-0240 or via email at tyson.ingels@state.co.us.

Sincerely,

Tyson Ingels

Lead Drinking Water Engineer
Water Quality Control Division
Colorado Department of Public Health and Environment

ec:

ALEX ARINELLO - ALEXA@SUPERIORCOLORADO.GOV;

R WAYNE RAMEY - wayner@recinc.net;

R WAYNE RAMEY - wayner@recinc.net;

SUPERIOR MD NO 1 {Owner Last Name} - JIMW@SUPERIORCOLORADO.GOV;

Erin Dodge - edodge@bouldercounty.org; Boulder County Public Health

Nicole Rowan, Water Quality Control Division Director, CDPHE

Ron Falco, WQCD SDW Program Manager

Bret Icenogle, WQCD ES Manager

Heather Young, WQCD FSS Manager

Nicole Graziano, WQCD DWCAS Manager

Jorge Delgado, WQCD DWCAS Compliance North Unit Manager

Margaret Talbott, WQCD DWCAS Compliance South Unit Manager

MaryAnn Nason, WQCD Communications and Special Projects Unit Manager

Drinking Water Acute Response Team, WQCD

Deborah Nelson, Environmental Health and Protection Operations Manager, CDPHE

Trisha Oeth, Director of Environmental Policy, CDPHE

Christina Postolowski, Mobile Home Park Oversight Program, DOLA, MHPOP@state.co.us

Sean Scott, DEHS, CDPHE

Ann Nedrow, Office of Emergency Preparedness and Response, CDPHE

Pam Pergande, Office of Emergency Preparedness and Response, CDPHE

Rachel Jervis, DCPHR, CDPHE

Seth Browning, DCPHR, CDPHE

Allison Wheeler, DCPHR, CDPHE

Christina Postolowski, Mobile Home Park Oversight Program, DOLA, MHPOP@state.co.us Bob Pohl - NORTH - B SW WQCD DWCAS Compliance Specialist

File: CO0107725, BOULDER, Community - Surface Water